

Voltage Profile Augmentation and Minimization of Real Power Loss in Transmission Lines by using Improved Hybrid Particle Swarm Optimization-Based on Harmony Search Algorithm

K. Lenin¹

¹ Jawaharlal Nehru Technological University Kukatpally

Received: 9 December 2013 Accepted: 1 January 2014 Published: 15 January 2014

Abstract

In this paper, a new particle swarm search algorithm is proposed to solve the optimal reactive power dispatch (ORPD) Problem. The ORPD problem is formulated as a nonlinear constrained single-objective optimization problem where the real power loss and the bus voltage deviations are to be minimized separately. As an optimization technique, particle swarm optimization (PSO) has obtained much attention during the past decade. It is gaining popularity, especially because of the speed of convergence and the fact that it is easy to realize. To enhance the performance of PSO, an improved hybrid particle swarm optimization (IHPSO) is proposed to solve complex optimization problems more efficiently, accurately and reliably. It provides a new way of producing new individuals through organically merges the harmony search (HS) method into particle swarm optimization (PSO). During the course of evolution, harmony search is used to generate new solutions and this makes IHPSO algorithm have more powerful exploitation capabilities. In order to evaluate the performance of the proposed algorithm, it has been tested on IEEE 30 bus system.

Index terms— modal analysis, optimal reactive power, transmission loss, particle swarm, harmony search metaheuristic.

1 Introduction

In recent years the optimal reactive power dispatch (ORPD) problem has received great attention as a result of the improvement on economy and security of power system operation. Solutions of ORPD problem aim to minimize object functions such as fuel cost, power system losses, etc. while satisfying a number of constraints like limits of bus voltages, tap settings of transformers, reactive and active power of power resources and transmission lines and a number of controllable Variables [1,2]. In the literature, many methods for solving the ORPD problem have been done up to now. At the beginning, several classical methods such as gradient based [3], interior point [4], linear programming [5] and quadratic programming [6] have been successfully used in order to solve the ORPD problem. However, these methods have some disadvantages in the Process of solving the complex ORPD problem. Drawbacks of these algorithms can be declared insecure convergence properties, long execution time, and algorithmic complexity. Besides, the solution can be trapped in local minima [1,7]. In order to overcome these disadvantages, researches have successfully applied evolutionary and heuristic algorithms such as Genetic Algorithm (GA) [2], Differential Evolution (DE) [8], Particle Swarm Optimization (PSO) [9] and harmony search algorithms [10][11]. This paper formulates the reactive power dispatch as a multi-objective optimization problem with loss minimization and maximization of static voltage stability margin (SVSM) as the objectives. Voltage stability evaluation using modal analysis [12] is used as the indicator of voltage stability. Function optimization has received extensive research attention, and several optimization algorithm such as neural networks [13], evolutionary algorithms [14], genetic algorithms [15] and swarm intelligence-based algorithms

[16][17] have been developed and applied successfully to solve a wide range of complex optimization problems. Most stochastic optimization algorithms including particle swarm optimizer (PSO) [18,19] and genetic algorithm (GA) [15] have shown inadequate to complex optimization problems, as they rapidly push an artificial population toward convergence. That is, all individuals in the population soon become nearly identical. To improve PSO performance, several methods have been proposed. Many of these methods concerned predefining numerical coefficients, consisting of the maximum velocity, inertia weight, social factor and individual factor, which can affect various characteristics of the algorithm, such as convergence rate or the ability of global optimization. Recently, some hybrid I Global Journal of Researches in Engineering () methods. NM-PSO (Nelder-Mead-PSO) [20] comprises NM method at the top of level, and PSO at the lower level. CPSO (Chaotic PSO) [21] applies PSO to perform global exploration and chaotic local search to perform local search on the solutions produced in the global exploration process. These methods can equip PSO with extra facilities. In this paper, an improved PSO (IPSO) based of harmony search (HS) [22,23] is proposed to solve complex optimizations. The PSO algorithm includes some tuning parameters that greatly influence the algorithm performance, often stated as the exploration-exploitation trade off: Exploration is the ability to test various regions in the problem space in order to locate a good optimum, hopefully the global one. Exploitation is the ability to concentrate the search around a promising candidate solution in order to locate the optimum precisely.

Facing complicated optimizations, it's difficult to explore every possible region of the search space. Recently, harmony search (HS) algorithm imitates the improvisation process of music players and had been very successful in a wide variety of optimization problems [24][25], presenting several advantages with respect to traditional optimization techniques such as the following [24]:(a) HS algorithm imposes fewer mathematical requirements and does not require initial value settings of the decision variables. (b) As the HS algorithm uses stochastic random searches, derivative information is also unnecessary. (c) The HS algorithm generates a new vector, after considering all of the existing vectors, whereas the genetic algorithm (GA) only considers the two parent vectors. These features increase the flexibility of the HS algorithm and produce better solutions. In this study, one of the ways of integrating the concepts of these two optimization algorithms for solving complex optimization problems is explored. The performance of IHPSO has been evaluated in standard IEEE 30 bus test system and the results analysis shows that our proposed approach outperforms all approaches investigated in this paper.

2 II.

3 Voltage Stability Evaluatio a) Modal analysis for voltage stability evaluation

The linearized steady state system power flow equations are given by. $\hat{V} = J^{-1} \Delta P$ Incremental change in bus voltage Magnitude J^{-1} , $J^{-1} \Delta P$, $J^{-1} \Delta Q$, $J^{-1} \Delta V$ jacobian matrix are the sub-matrixes of the System voltage stability is affected by both P and However at each operating point we keep P constant and evaluate voltage stability by considering incremental relationship between and V. $\Delta V = J^{-1} \Delta P$ (1)

To reduce (1), let $\hat{V} = 0$, then. $\Delta Q = J^{-1} \Delta P$ (2) $\Delta V = J^{-1} \Delta P$ (3)

Where $J^{-1} = J^{-1} \Delta Q$ (4)

J^{-1} is called the reduced Jacobian matrix of the system.

4 a) Modes of Voltage instability

Voltage Stability characteristics of the system can be identified by computing the eigen values and eigen vectors Let $J^{-1} = J^{-1}$ (5)

Where, λ = right eigenvector matrix of J^{-1} μ = left eigenvector matrix of J^{-1} Λ = diagonal eigenvalue matrix of J^{-1} and $J^{-1} \mu = \Lambda^{-1} \mu$ (6)

From (3) and (6), we have $\Delta V = \Lambda^{-1} \Delta P$ (7)

or $\Delta V = \mu \lambda^{-1} \Delta P$ (8)

Where μ is the ith column right eigenvector and λ the ith row left eigenvector of J^{-1} . λ is the ith eigen value of J^{-1} . The ith modal reactive power variation is, $\Delta Q_{mi} = K_i \lambda_i$ (9)

where, $K_i = \mu_{ij} \lambda_j^{-1}$ (10)

Where μ_{ji} is the jth element of μ i

The corresponding ith modal voltage variation is $\Delta V_{mi} = [1 \ \lambda_i^{-1}] \Delta Q_{mi}$ (11)

In (8), let $\hat{V} = e_k$ where e_k has all its elements zero except the kth one being 1. Then, Global Journal of Researches in Engineering () $\Delta Q = J^{-1} \Delta P$ (12) ΔQ_{mi} k th element of ΔV -Q sensitivity at bus k $\Delta V_{mi} = K_i \lambda_i^{-1}$ (13) III.

5 PROBLEM FORMULATION

The objectives of the reactive power dispatch problem considered here is to minimize the system real power loss and maximize the static voltage stability margins (SVSM).

6 a) Minimization of Real Power Loss

Minimization of the real power loss (Ploss) in transmission lines of a power system is mathematically stated as follows. $P_{loss} = \sum_{k=1}^n g_k (V_i^2 + V_j^2 - 2V_i V_j \cos \theta_{ij})$ (14)

Where n is the number of transmission lines, g_k is the conductance of branch k , V_i and V_j are voltage magnitude at bus i and bus j , and θ_{ij} is the voltage angle difference between bus i and bus j .

7 b) Minimization of Voltage Deviation

Minimization of the Deviations in voltage magnitudes (VD) at load buses is mathematically stated as follows. Minimize $VD = \sum_{k=1}^{nl} |V_k - 1.0|$ (15)

Where nl is the number of load busses and V_k is the voltage magnitude at bus k .

8 c) System Constraints

In the minimization process of objective functions, some problem constraints which one is equality and others are inequality had to be met. Objective functions are subjected to these constraints shown below.

9 Load flow equality constraints:

$\sum_{g=1}^{ng} P_g - \sum_{d=1}^{nd} P_d - \sum_{ij=1}^{nb} G_{ij} (V_i^2 + V_j^2) - \sum_{ij=1}^{nb} B_{ij} V_i V_j \sin \theta_{ij} = 0$, $\theta_{ij} = 1, 2, \dots, nb$ (16)
 $\sum_{g=1}^{ng} Q_g - \sum_{d=1}^{nd} Q_d - \sum_{ij=1}^{nb} G_{ij} V_i V_j \sin \theta_{ij} + \sum_{ij=1}^{nb} B_{ij} (V_i^2 + V_j^2) \cos \theta_{ij} = 0$, $\theta_{ij} = 1, 2, \dots, nb$ (17)

where, nb is the number of buses, P_g and Q_g are the real and reactive power of the generator, P_d and Q_d are the real and reactive load of the generator, and G_{ij} and B_{ij} are the mutual conductance and susceptance between bus i and bus j .

Generator bus voltage (V_{Gi}) inequality constraint: $V_{Gi}^{min} \leq V_{Gi} \leq V_{Gi}^{max}$, $i = 1, 2, \dots, ng$ (18)

Load bus voltage (V_{Li}) inequality constraint: $V_{Li}^{min} \leq V_{Li} \leq V_{Li}^{max}$, $i = 1, 2, \dots, nd$ (19)

Switchable reactive power compensations (Q_{Ci}) inequality constraint: $Q_{Ci}^{min} \leq Q_{Ci} \leq Q_{Ci}^{max}$, $i = 1, 2, \dots, nc$ (20)

Reactive power generation (Q_{Gi}) inequality constraint: $Q_{Gi}^{min} \leq Q_{Gi} \leq Q_{Gi}^{max}$, $i = 1, 2, \dots, ng$ (21)

Transformers tap setting (T_i) inequality constraint: $T_i^{min} \leq T_i \leq T_i^{max}$, $i = 1, 2, \dots, nt$ (22)

Transmission line flow (S_{Li}) inequality constraint: $S_{Li}^{min} \leq S_{Li} \leq S_{Li}^{max}$, $i = 1, 2, \dots, nt$ (23)

Where, nc , ng and nt are numbers of the switchable reactive power sources, generators and transformers.

IV.

10 STANDARD PSO

PSO is a population-based, co-operative search meta-heuristic introduced by Kennedy and Eberhart. The fundament for the development of PSO is hypothesis that a potential solution to an optimization problem is treated as a bird without quality and volume, which is called a particle, coexisting and evolving simultaneously based on knowledge sharing with neighbouring particles. While flying through the problem search space, each particle modifies its velocity to find a better solution (position) by applying its own flying experience (i.e. memory having best position found in the earlier flights) and experience of neighbouring particles (i.e. best-found solution of the population). Particles update their positions and velocities as shown below: $v_i^{t+1} = \delta v_i^t + c_1 r_1 (p_{best} - p_i^t) + c_2 r_2 (g_{best} - p_i^t)$ (24) $p_i^{t+1} = p_i^t + v_i^{t+1}$ (25)

Where p_i^t represents the current position of particle i in solution space and subscript t indicates an iteration count; p_{best} is the best-found position of particle i up to iteration count t and represents the cognitive contribution to the search velocity v_i^t . Each component of v_i^t can be clamped to the range to control excessive roaming of particles outside the search space; g_{best} is the global best-found position among all particles in the swarm up to iteration count t and forms the social contribution to the velocity vector; r_1 and r_2 are random numbers uniformly distributed in the interval (0,1), where c_1 and c_2 are the cognitive and social scaling parameters, respectively; δ is the particle inertia, which is reduced dynamically to decrease the search area in a gradual fashion [25]. The variable δ is updated as

11 Global Journal of Researches in Engineering (

) $\delta = (\delta_{max} - \delta_{min}) \frac{iter}{iter_{max}} + \delta_{min}$ (26)

Where δ_{max} and δ_{min} denote the maximum and minimum of δ respectively; $iter_{max}$ is a given number of maximum iterations. Particle i fly toward a new position according to Eq. (24) and (25). In this way, all particles of the swarm find their new positions and apply these new positions to update their individual best points and global best of the swarm. This process is repeated until termination conditions are met.

V.

12 HARMONY SEARCH

Harmony search (HS) algorithm is based on natural musical performance processes that occur when a musician searches for a better state of harmony, such as during jazz improvisation. The engineers seek for a global solution as determined by an objective function, just like the musicians seek to find musically pleasing. The steps in the procedure of harmony search are as follows:

- Step 1: Initialize the problem and algorithm parameters.
- Step 2: Initialize the harmony memory (HM).
- Step 3: Improvise a new harmony from the HM.
- Step 4: Update the HM.
- Step 5: Repeat Steps 3 and 4 until the termination criterion is satisfied.

13 VI. THE REALIZATION OF IHPSO BASED OF HS

This section describes the implementation of proposed improvement in PSO using HS approach. The proposed method, called, IHPSO (improved hybrid particle swarm optimization) is based on the common characteristics of both PSO and HS algorithms. HS algorithm provides a new way to produce new particles. Different from PSO and GA, HS algorithm generates a new vector after considering all of the existing vectors. HS algorithm can produce new solution and the parameters of HMCR and PAR are introduced to allow the solution to escape from local optima and to improve the global optimum prediction of the algorithm. Enlightened by this, the HS realization concept has been used in the PSO in this paper to exploration the potential solution space. In summary, the realization of improved PSO algorithm for solving reactive power dispatch is described as follows:

- Step 1: Initializing the parameters of PSO and HS;
- Step 2: Initializing the particles;
- Step 3: Evaluating particles according to their fitness then descending sort them;
- Step 4: Performing HS and generating a new solution;
- Step 5: If the new solution is better than the worst particle then replacing it with the new one;
- Step 6: Update the particles by using equation's (24) & (25) Step 7: The program is finished if the terminations conditions are met otherwise go to step3.

Improvising a new harmony from the HM can be realized as follows:

A New Harmony vector $H_{new} = \{H_{new}^1, H_{new}^2, \dots, H_{new}^n\}$ is generated from the HM based on memory considerations, pitch adjustments, and randomization. For instance, the value of for the new vector can be chosen from any value in the specified HM range $[H_{min}^i, H_{max}^i]$ harmony as determined by an aesthetic [26]- [27]. In music improvisation, each player sounds any pitch within the possible range, together making one harmony vector. If all the pitches make a good solution, that experience is stored in each variable's memory, and the possibility to make a good solution is also increased next time. HS algorithm includes a number of optimization operators, such as the harmony memory (HM), the harmony memory size (HMS, number of solution vectors in harmony memory), the harmony memory considering rate (HMCR), and the pitch adjusting rate (PAR). In the HS algorithm, the harmony memory (HM) stores the feasible vectors, which are all in the feasible space. The harmony memory size determines how many vectors it stores. A new vector is generated by selecting the components of different vectors randomly in the harmony memory. For example, Consider a jazz trio composed of saxophone, double bass and guitar. There exist certain amount of preferable pitches in each musician's memory: saxophonist, {Do, Mi, Sol}; double bassist, {Si, Sol, Re}; and guitarist, {La, Fa, Do}. If saxophonist randomly plays {Sol} out of {Do, Mi, Sol}, double bassist {Si} out of {Si, Sol, Re}, and guitarist {Do} out of {La, Fa, Do}, that harmony (Sol, Si, Do) makes another harmony (musically C-7 chord). And if the New Harmony is better than existing worst harmony in the HM, the New Harmony is included in the HM and the worst harmony is excluded from the HM. This procedure is repeated until fantastic harmony is found. When a musician improvises one pitch, usually he (or she) follows any one of three rules: (a) playing any one pitch from his (or her) memory, (b) playing an adjacent pitch of one pitch from his (or her) memory, and (c) playing totally random pitch from the possible sound range. Similarly, when each decision variable chooses one value in the HS algorithm, it follows any one of three rules: (i) choosing any one value from HS memory (defined as memory considerations), (ii) choosing an adjacent value of one value from the HS memory (defined as pitch adjustments), and (iii) choosing totally random value from the possible value range (defined as randomization). The three rules in HS algorithm are effectively directed using two parameters, i.e., harmony memory considering rate (HMCR) and pitch adjusting rate (PAR).

chosen in the same manner. Here, it's possible to choose the new value using the HMCR parameter, which varies between 0 and 1 as follows: $H_{new}^i = \begin{cases} H_{old}^i & \text{if } rand() < HMCR \\ H_{rand}^i & \text{otherwise} \end{cases}$ (27)

The HMCR is the probability of choosing one value from the historic values stored in the HM, and (1-HMCR) is the probability of randomly choosing one feasible value not limited to those stored in the HM. For example, an HMCR of 0.95 indicates that the HS algorithm will choose the design variable value from historically stored values in the HM with a 95% probability and from the entire feasible range with a 5% probability. An HMCR value of 1.0 is not recommended because of the possibility that the solution may be improved by values not stored in the HM. This is similar to the reason why the genetic algorithm uses a mutation rate in the selection process. Every component of the New Harmony vector $H_{new} = \{H_{new}^1, H_{new}^2, \dots, H_{new}^n\}$ is examined to determine whether it should be pitch-adjusted. This procedure uses the parameter that set the rate of adjustment for the pitch

216 chosen from the HM as follows: Pitch adjusting decision for?? ?? ? ? ? ?????? ??????? ??????????????????????
 217 ?????? ??? ?????? ?????????????????????? 1 ? ??????(28)

218 The Pitch adjusting process is performed only after a value is chosen from the HM. The value (1-PAR) sets
 219 the rate of doing nothing. A PAR of 0.3 indicates that the algorithm will choose a neighbouring value with
 220 probability. If the pitch adjustment decision for ?? ? is Yes, and ?? ? is assumed to be ?? ?? (??) i.e., the kth
 221 element in ?? ?? , the pitch-adjusted value of?? ?? (??) is:?? ? = ?? ? + ??(29)

222 Where ?? ? the value of is ????? ? (1, ?1), ????? is an arbitrary distance bandwidth for the continuous design
 223 variable, and u (?1, 1) is a uniform distribution between -1 and 1. The HMCR and PAR parameters introduced
 224 in the harmony search help the algorithm escape from local optima and to improve the global optimum prediction
 225 of the HS algorithm. After improvising a new harmony, evaluating the new one and if it is better than the worst
 226 one in the HM in terms of the objective function value, the new one is included in the HM and the existing worst
 227 harmony is excluded from the HM. The HM is then sorted by the objective function value.

228 14 VII.

229 15 SIMULATION RESULTS

230 The accuracy of the proposed IHPSO Algorithm method is demonstrated by testing it on standard IEEE-30
 231 bus system. The IEEE-30 bus system has 6 generator buses, 24 load buses and 41 transmission lines of which
 232 four branches are (6-9), (6-10) , (4-12) and (28-27) -are with the tap setting transformers. The lower voltage
 233 magnitude limits at all buses are 0.95 p.u. and the upper limits are 1.1 for all the PV buses and 1.05 p.u. for
 234 all the PQ buses and the reference bus. The simulation results have been presented in Tables 1, 2, 3 &4. And
 235 in the Table ?? shows the proposed algorithm powerfully reduces the real power losses when compared to other
 236 given algorithms. The optimal values of the control variables along with the minimum loss obtained are given
 237 in Table 1. Corresponding to this control variable setting, it was found that there are no limit violations in any
 238 of the state variables. ORPD together with voltage stability constraint problem was handled in this case as a
 239 multi-objective optimization problem where both power loss and maximum voltage stability margin of the system
 240 were optimized simultaneously. Table 2 indicates the optimal values of these control variables. Also it is found
 241 that there are no limit violations of the state variables. It indicates the voltage stability index has increased from
 242 0.2482 to 0.2498, an advance in the system voltage stability. To determine the voltage security of the system,
 243 contingency analysis was conducted using the control variable setting obtained in case 1 and case 2. The Eigen
 244 values equivalents to the four critical contingencies are given in Table 3. From this result it is observed that the
 Eigen value has been improved considerably for all contingencies in the second case. ^{1 2 3}



Figure 1: WhereÎ?”P=

1

Variables	Variable setting
Control variables	
V1	1.040
V2	1.041
V5	1.040
V8	1.030
V11	1.003
V13	1.041
T11	1.01
T12	1.00
T15	1.0
T36	1.0
Qc10	3
Qc12	4
Qc15	4
Qc17	0
Qc20	3
Qc23	4
Qc24	3
Qc29	3
Real power loss	4.2985
SVSM	0.2482

Figure 2: Table 1 :

2

Control Variables	Variable Setting
V1	1.043
V2	1.044
V5	1.042
V8	1.031
V11	1.005
V13	1.035
T11	0.090
T12	0.090
T15	0.090
T36	0.090
Qc10	4
Qc12	4
Qc15	3
Qc17	4
Qc20	0
Qc23	3
Qc24	3
Qc29	4
Real power loss	4.9690
SVSM	0.2498

Figure 3: Table 2 :

3

Sl.No	Contingency	ORPD Setting	Method	Minimum loss
			Evolutionary programming[28]	5.0159
			Genetic algorithm[29]	4.665
			Real coded GA with Lindex as SVSM[30]	4.568
			Real coded genetic algorithm[31]	4.5015
			Proposed IHPSO method	4.2985
			VSCRPD	
1	28-27	0.1410	Setting	0.1425
2	4-12	0.1658		0.1665
3	1-3	0.1774		0.1783
4	2-4	0.2032		0.2045

[Note: www.GlobalJournals.org]

Figure 4: Table 3 :

¹© 2014 Global Journals Inc. (US) implementations of PSO algorithm with other search

²© 2014 Global Journals Inc. (US)

³© 2014 Global Journals Inc. (US) Voltage Profile Augmentation and Minimization of Real Power Loss in Transmission Lines by using

.1 CONCLUSION

245
246
247
248
249
250
251
252
253
254
255
256
257
258
259
260
261
262
263
264
265
266
267
268
269
270
271
272
273
274
275
276
277
278
279
280
281
282
283
284
285
286
287
288
289
290
291
292
293
294
295
296
297
298
299

In this paper, one of the recently developed stochastic algorithms IHPSO has been demonstrated and applied to solve optimal reactive power dispatch problem. The problem has been formulated as a constrained optimization problem. Different objective functions have been considered to minimize real power loss, to enhance the voltage profile. The proposed approach is applied to optimal reactive power dispatch problem on the IEEE 30-bus power system. The simulation results indicate the effectiveness and robustness of the proposed algorithm to solve optimal reactive power dispatch problem in test system.

[Geem et al. ()] ‘A new heuristic optimization algorithm: harmony search’. Z W Geem , J H Kim , G V Loganathan . *Simulation* 2001. 76 (2) p. .

[Lee and Geem ()] ‘A new meta-heuristic algorithm for continues engineering optimization: harmony search theory and practice’. K S Lee , Z W Geem . *Comput. Meth. Appl. Mech. Eng* 2004. 194 p. .

[Eberhart and Kennedy ()] ‘A new optimizer using particle swarm theory’. R C Eberhart , J Kennedy . *Proceedings of the Sixth International Symposium on Micromachine and Human Science, (the Sixth International Symposium on Micromachine and Human Science Nagoya, Japan)* 1995. p. .

[Kang and Geem ()] ‘A new structural optimization method based on the harmony search algorithm’. S L Kang , Z W Geem . *Comput. Struct* 2004. 82 (9) p. .

[Abido and Bakhshwain ()] ‘A novel multiobjective evolutionary algorithm for optimal reactive power dispatch problem’. M A Abido , J M Bakhshwain . *proc. Electronics, Circuits and Systems conf, (Electronics, Circuits and Systems conf)* 2003. 3 p. .

[Holland ()] *Adaptation in Natural and Artificial Systems*, J H Holland . 1975. MIT Press.

[Deeb and Shahidehpour ()] ‘An Efficient Technique for Reactive Power Dispatch Using a Revised Linear Programming Approach’. N I Deeb , S M Shahidehpour . *Electric Power System Research* 1988. 15 p. .

[Bishop ()] C M Bishop . *Neural Networks for Pattern Recognition*, 1995. Oxford University Press.

[Canizares et al. (1996)] *Comparison of performance indices for detection of proximity to voltage collapse*, C A Canizares , A C Z Souza , V H Quintana . Aug 1996. 11 p. .

[Abou El Ela et al. ()] ‘Differential Evolution Algorithm for Optimal Reactive Power Dispatch’. A A Abou El Ela , M A Abido , S R Spea . *Electric Power Systems Research* 2011. 81 p. .

[Miranda and Fonseca ()] ‘EPSO-Evolutionary Particle Swarm Optimization, A New Algorithm with Applications in Power Systems’. V Miranda , N Fonseca . *Proc. of Transmission and Distribution conf, (of Transmission and Distribution conf)* 2002. 2 p. .

[Lee et al. ()] *Fuel-cost minimisation for both real and reactive-power dispatches*, K Y Lee , Y M Park , J L Ortiz . 1984. 131 p. . (in proc. Generation, Transmission and Distribution conf)

[Engelbrecht ()] *Fundamentals of Computational Swarm Intelligence*, A P Engelbrecht . 2005. John Wiley & Sons.

[Durairaj et al. (2006)] ‘Genetic algorithm applications to optimal reactive power dispatch with voltage stability enhancement’. S Durairaj , D Devaraj , P S Kannan . *IE(I) Journal-EL* September 2006. 87.

[Abdullah et al. ()] ‘Genetic Algorithm for Optimal Reactive Power Dispatch’. W N W Abdullah , H Saibon , A A M Zain , K L Lo . *proc. Energy Management and Power Delivery conf, (Energy Management and Power Delivery conf)* 1998. 1 p. .

[T. Back, D.B. Fogel, A. Michalewicz (ed.) ()] *Handbook of Evolutionary Computation*, T. Back, D.B. Fogel, A. Michalewicz (ed.) 1997. IOP Publishers and Oxford University Press.

[Geem et al. ()] ‘Harmony search for generalized orienteering problem: best touring in China’. Z W Geem , C Tseng , Y Park . *Lecture Notes in Computer Science* 2005. Springer. 3412 p. .

[Geem et al. ()] ‘Harmony search optimization: application to pipe network design’. Z W Geem , J H Kim , G V Loganathan . *Int.J.Model. Simul* 2002. 22 (2) p. .

[Fan et al. ()] ‘Hybrid simplex search and particle swarm optimization for the global optimization of multimodal functions’. S K S Fan , Y C Liang , E Zahara . *Engineering Optimization* 2004. 36 (4) p. .

[Devaraj ()] ‘Improved genetic algorithm for multiobjective reactive power dispatch problem’. D Devaraj . *European Transactions on electrical power* 2007. 17 p. .

[Liu et al. ()] ‘Improved particle swarm optimization combined with chaos’. B Liu , L Wang , Y H Jin , F Tang , D X Huang . *Chaos Solitons & Fractals* 2005. 25 p. .

[Geem (ed.) ()] *Knowledge-based intelligent information and engineering systems*, Z Geem . Gabrys B, Howlett R.J, Jain L (ed.) 2006. Heidelberg: Springer. p. . (Improved harmony search from ensemble of music players)

[Abido ()] ‘Optimal Power Flow Using Particle Swarm Optimization’. M A Abido . *Electrical Power and Energy Systems* 2002. 24 p. .

- 300 [Granville ()] ‘Optimal Reactive Dispatch Trough Interior PointMethods’. S Granville . *IEEE Trans. on Power*
301 *Systems* 1994. 9 p. .
- 302 [Jeyanthi and Devaraj (2010)] ‘Optimal Reactive Power Dispatch for Voltage Stability Enhancement Using Real
303 Coded Genetic Algorithm’. P , Aruna Jeyanthi , Dr D Devaraj . *International Journal of Computer and*
304 *Electrical Engineering* August. 2010. 2 (4) p. .
- 305 [Geem ()] ‘Optimal scheduling of multiple dam system using harmony search algorithm’. Z Geem . *Computation-*
306 *aland ambient intelligence*, (Berlin) 2007a. Springer. p. .
- 307 [Kim et al. ()] ‘Parameter estimation of the nonlinear Muskingum model using harmony search’. J H Kim , Z W
308 Geem , E S Kim . *J.Am. Water Resour. Assoc* 2001. 37 (5) p. .
- 309 [Kennedy J et al. ()] ‘Particle swarm optimization’. Kennedy J , Eberhart R C. ; R] , Piscataway . *Proceedings of*
310 *IEEE International Conference on Neural Networks*, (IEEE International Conference on Neural NetworksNJ)
311 1995. IEEE Press. 4 p. .
- 312 [Wu and Ma ()] ‘Power system optimal reactive power dispatch using evolutionary programming’. Q H Wu , J
313 Ma . *IEEE Transactions on power systems* 1995. 10 (3) p. .
- 314 [Grudinini ()] ‘Reactive Power Optimization Using Successive QuadraticProgramming Method’. N Grudinini .
315 *IEEE Trans. on Power Systems* 1998. 13 p. .
- 316 [Kennedy and Eberhart ()] *Swarm Intelligence*, J Kennedy , R C Eberhart . 2001. Morgan Kaufman.