

Assessment of Energy Security of the Region on the Example of Pridnestrovye

S.G. Fedorchenko¹ and G.S. Fedorchenko²

¹ Pridnestrovian State University, Tiraspol

Received: 15 June 2021 Accepted: 4 July 2021 Published: 15 July 2021

Abstract

Article is devoted to a problem of assessment of energy security of the region. The indicative analysis, function of usefulness of Harington-Menchera is applied. While assessing the level of energy security it is offered to consider the mode of functioning of the region power system. The offered technique is used for assessment of energy security of Pridnestrovye

Index terms— energy security, the generalized function of usefulness, indicator method, correlation groups.

1 Introduction

Earlier we offered [1,2,3] to use an integrated indicator while forming the assessment of the region energy security: -A set of the indicators characterizing energy security of the explored region [3]; -The range of critical variables they relate to energy independence as set up by the individual conducting the study [1,2]; -Harington-Menchera function [8].

We use the technique offered by us of creation of an integrated indicator of energy security of Pridnestrovye.

2 II.

3 Pre-Processing of Data

We use the technique offered by us of creation of an integrated indicator of energy security of Pridnestrovye.

According to our technique previously it is necessary to transform values of indicators to values of dimensionless function of usefulness which we will call as private indicators of quality. This transformation is described in detail [4].

The technique used while forming an integrated indicator of energy security demands the values of the indicators used by us to be not correlated. For checking of implementation of this requirement we use the method of correlation groups [5].

At assessment of the size of energy security of Pridnestrovye we used 16 indicators. The range of critical variables was borrowed (with some changes) from [6]. As the value characterizing a group is used the average value of private indicators of quality along all the members of a group. The values of the scales received by us as a result of poll experts' are presented in the right TABLE I column.

Data for calculation of the generalized function of usefulness are consolidated in Table 2. Calculations given in Table 2 are executed for normal working hours of power supply system [7]. It is obvious that in other working hours of power supply system, weight coefficients of indicators will change that will affect value of an integrated indicator. The example of similar calculations is given in Table 3. We received the values of scales as a results of experts' poll.

It is visible in Table 3 that weight of indicators very strongly depend on working hours of power supply system, so, at critical operating modes the value of economic indicators decreases (z13, z16) and the role of the indicator (z2) increases.

41 4 IV.

42 5 Analysis of the Obtained Results

43 On closer examination Table 3 it is visible that in process of deterioration in a working hours of power supply
 44 system, the value of the combined integrated indicator of energy security of D falls. We need to find the reason
 45 causing this change.

46 Let's transform the formula on which there is a calculation of the generalized function of usefulness, as follows:
 47 $3 \cdot 2 \cdot 1 / 4 / 3 / 2 / 1 \cdot 4 \cdot 3 \cdot 2 \cdot 1 \cdot 4 \cdot 3 \cdot 2 \cdot 1 \cdot 4 \cdot 3 \cdot 2 \cdot 1 \cdot D \cdot D \cdot D \cdot d \cdot d \cdot d \cdot d \cdot d \cdot d \cdot d \cdot d \cdot d \cdot d = = ? ? ? ? + + + = ? ? ? ?$
 48 $? ? ? ? ? ? ? ? ? ?$

49 .
 50 (
 51 Here D1, D2, D3, D4 are factors of the combined integrated indicator of EB.

52 Let's execute calculations of D1, D2, D3, D4 values and we will construct on them the schedules presented on
 53 Fig 3, 4.

54 These schedules show that in process of working hours of power supply system changing (at invariable values
 55 of indicators, but the changing values of their scales), D2 factor size -a share of the dominating fuel in total fuel
 56 quantity falls that involves falling of size of all integrated indicator of ES. F

57 The schedule of size D2 dependence on working hours of power supply system is presented on Fig 5 it is visible
 58 that to a measure of deterioration in a working hours of power supply system size D2 decreases, and since the
 59 mode of functioning No. 5, passes into a zone of values "unsatisfactorily" (size $D < 0.37$).

60 We made an attempt to number the estimate influence of possible values z2 indicators on energy security
 61 of the region, at invariable values of other indicators. Values of the indicator from 50% to 98% are for this
 62 purpose changed and the size of the combined integrated indicator of energy security of the region -D is counted.
 63 Calculation results are given in Table 4, 5. 4 contains the values D calculated for various values of the z2 indicator.
 64 In the table values which are less, than 0.37 are highlighted in bold. It demonstrates that the power supply system
 65 of the region is in an unsatisfactory state. Values, smaller, than 0.2 are corresponded to a condition of the system
 66 "very badly". It is visible that these estimates depend on the mode of functioning of the region power system.
 67 So in modes No. 1, 2 at any values of the z2 indicator the system will not be in an unsatisfactory state, in modes
 68 No. 7, 8, for ensuring satisfactory work of power supply system, the value of the z2 indicator has to be less than
 69 82%. For comparison we will consider the same results of calculation, but we will compare the received values
 70 to number 0.63 -border of good and satisfactory functioning of power supply system. The received results are
 71 given in Table 5. From the table it is visible that for ensuring good functioning of a system the value of the z2
 72 indicator in the 8th mode has to be less than 66%, and in the 1st mode -less than 90%.

73 Relying on the values given above, it is possible to claim that for increase in level of energy security of power
 74 supply system of the region, it is necessary to have an opportunity, to reduce a share of the dominating fuel at
 75 the modes of functioning of power supply system other than normal. Let's consider one of possible options of
 76 such actions is the translation of the unit of the Pridnestrovian state district power plant which provides with
 77 the electric power Pridnestrovye on other type of fuel -coal. It is known that the Pridnestrovian state district
 78 power plant has the corresponding equipment which is in the preserved state now.

79 The state district power plant uses from 30% to 40% of the gas consumed by Pridnestrovye. It allows to
 80 claim that conversion of the corresponding unit of state district power plant to coal will allow to reduce a share
 81 of the dominating fuel by 27-36%, that is the indicator that accepts values in the range from 60% up to 55%.
 82 From tables 4, 5 it is clear that it will allow, to increase the level of energy security of the region for satisfactory
 83 condition, regardless of the mode of functioning of power supply system. ¹

¹© 2021 Global Journals

1

	z9	0,836 0,978	z12	1	z4		I Year 2021
	z7	0,944	z10	0,934	z1 z14 0,957 0,928	z15 0,963	ersion I
z2	0,62		z3 0,986		z5 0,966	z11	
II 0,605							
z16	0,51		z13	0,66	z8	0,998	z6
	III	IV			V		
z2 IV 0,605							
z16	0,51		z13	0,58	z1	0,72	z8
	III	II			I		

[Note: Let's find the average value of private functions of usefulness of the indicators entering galaxy No. 1 and designate it as.]

Figure 1: Table 1 :

2

Codes	Description of an indicator	Group	Weight of groups ??
d 1 *	The average d1 value d1* on group No. 1	1	0,6
d 2	Share of the dominating fuel in total fuel quantity.	2	0,8
d 16	Energy investments.	3	0,5
d 13	Ratio of energy resources cost and average per capita income.	4	0,7

Figure 2: Table 2 :

5 ANALYSIS OF THE OBTAINED RESULTS

3

Mode of power supply system functioning	Z1*	Values of weight coefficients			The combined integrated indicator value of D
		z2	z16	z13	
Normal	0,8	0,1	0,5	0,9	0,545
Pre-crisis initial	0,8	0,2	0,45	0,75	0,444
Pre-crisis developing	0,8	0,3	0,4	0,7	0,363
Pre-crisis critical	0,8	0,4	0,4	0,65	0,301
Crisis unstable	0,8	0,5	0,35	0,6	0,254
Crisis menacing	0,8	0,7	0,3	0,55	0,184
Crisis critical	0,8	0,8	0,3	0,5	0,16
Crisis extraordinary	0,8	0,9	0,25	0,4	0,128

Figure 3: Table 3 :

4

No. of functioning of a system	mode	Values of the z2 indicator, in %							
		78	80	82	86	90	94	98	
Table	2	0,701	0,692	0,681	0,591	0,656	0,628	0,596	0,564
	3 4	0,627	0,610	0,530	0,488	0,547	0,498	0,446	0,398
	5 6	0,580	0,556	0,447	0,375	0,472	0,410	0,348	0,293
	7 8	0,550	0,520	0,348	0,306	0,420	0,350	0,282	0,226
		0,518	0,483			0,370	0,294	0,225	0,170
		0,457	0,416			0,291	0,214	0,149	0,103
		0,434	0,391			0,262	0,186	0,124	0,082
		0,394	0,350			0,221	0,149	0,094	0,058

Figure 4: Table 4 :

5

No. of functioning of a system mode		Values of the z2 indicator, in %								
		66	68	70	72	74	76	78	90	
Table	1	0,738	0,734	0,729	0,681	0,723	0,717	0,709	0,701	0,628
	2	0,699	0,69	0,656	0,645	0,67	0,657	0,643	0,627	0,498
	3	0,682	0,67	0,632	0,597	0,64	0,622	0,602	0,580	0,410
	4	0,678	0,663	0,586		0,625	0,602	0,577	0,550	0,350
	5	0,674	0,654			0,608	0,580	0,551	0,518	0,294
	6	0,65	0,625			0,566	0,532	0,496	0,457	0,214
	7	0,644	0,617			0,552	0,515	0,476	0,434	0,186
	8	0,620	0,590	0,556		0,519	0,480	0,438	0,394	0,149

Figure 5: Table 5 :

-
- 84 [Fedorchenko] *Calculation of values of the indicators characterizing energy security of Pridnestrovye//the*
85 *Messenger Pridnestr. un-that. Series: Physical. -a mat and technical. sciences*, G S Fedorchenko . p. .
- 86 [Fedorchenko ()] ‘Classification of the modes of functioning of power supply system of the region//Messenger
87 Prinestr. university. Series: Physical. -a mat and technical’. G S Fedorchenko . *Sciences* 2018. (3) p. .
- 88 [Fedorchenko and Fedorchenko ()] *Integrated measure of assessment of a condition of energy security//Problem*
89 *of regional energy. Academy of Sciences of the Moldova Republic*, G S Fedorchenko , S G Fedorchenko . 2014.
90 (Institute of power. electronic edition)
- 91 [Bykovo et al. ()] *Methodical recommendations of the solution of problems of energy security of Moldova and*
92 *Belarus*, E V Bykovo , E V Mikhaylevich , V M Postolaty . 2010. Chisinau. (100 pages)
- 93 [Druzhinin ()] *Methods of assessment and forecasting of quality*, G V Druzhinin . 1982. (Radio and communica-
94 tion. 160 pages)
- 95 [Fedorchenko and Fedorchenko ()] *Multiplicative integrated assessment of a condition of energy secu-*
96 *rity//Problems of regional energy. Academy of Sciences of the Moldova Republic*, G S Fedorchenko , S
97 G Fedorchenko . 2016.
- 98 [Fedorchenko and Fedorchenko ()] *Multiplicative integrated measure of assessment of a condition of energy*
99 *security//Messenger Pridnestr. university, Series: Physical. -a mat. and ????. sciences*, G S Fedorchenko ,
100 S G Fedorchenko . 2014. p. .
- 101 [Fedorchenko et al. ()] *The generalized function of usefulness and its application / Under the editorship of,*
102 *Fedorchenko. -Tiraspol: Pridnestr. university publishing house*, S G Fedorchenko , A Dolgov Yu , A V
103 Kirsanova . 2011. (196 pages)