

A Heuristic Method for Short Term Load Forecasting Using Historical Data Strictly as per the compliance and regulations of

Dr. D.V.Rajan¹

¹ NATIONAL INSTITUTE OF TECHNOLOGY, DURGAPUR, WB,INDIA

Received: 4 October 2011 Accepted: 29 October 2011 Published: 12 November 2011

Abstract

Load forecasting plays an important role in power system planning and operation. In the present complex power system network under deregulated regime, power generating companies must be able to forecast their system demand and the corresponding price in order to make appropriate market decisions. Therefore, load forecasting, specially the short-term load forecasting (STLF) plays an important role for energy efficient and reliable operation of a power system. It provides input data for many operational functions of power systems such as unit commitment, economic dispatch, and optimal power flow and security assessment. This paper proposes a new and simple technique to calculate short term load forecasting using historical data and applied it to the Damodar Valley Corporation (DVC) grid operating under Eastern Grid (ERLDC-Eastern Regional Load Despatch Centre), India. This gives load forecasts half an hour in advance. The forecast error i.e. difference between calculated forecast load and real time load is a measure of the accuracy of the system, is found to be lower than other existing techniques like Holt's Method, Chow's Adaptive Control Method, Brown's One-Parameter Adaptive Method.

Index terms— HM-Holt's Method, CACM-Chow's Adaptive Control Method, BOPAM-Brown's One-Parameter Adaptive Method, RTL-Real time load Mean Absolute Percentage

A Heuristic Method for Short Term Load Forecasting Using Historical Data D.V.Rajan¹, C.Saravanan², S.S.Thakur³ A Abstract-Load forecasting plays an important role in power system planning and operation. In the present complex power system network under deregulated regime, power generating companies must be able to forecast their system demand and the corresponding price in order to make appropriate market decisions. Therefore, load forecasting, specially the short-term load forecasting (STLF) plays an important role for energy efficient and reliable operation of a power system. It provides input data for many operational functions of power systems such as unit commitment, economic dispatch, and optimal power flow and security assessment. This paper proposes a new and simple technique to calculate short term load forecasting using historical data and applied it to the Damodar Valley Corporation (DVC) grid operating under Eastern Grid (ERLDC-Eastern Regional Load Despatch Centre), India. This gives load forecasts half an hour in advance. The forecast error i.e. difference between calculated forecast load and real time load is a measure of the accuracy of the system, is found to be lower than other existing techniques like Holt's Method, Chow's Adaptive Control Method, Brown's One-Parameter Adaptive Method. In the present day, there are many issues and challenges in the deregulated electric power industry worldwide. The Indian power sector is undergoing structural metamorphosis and the various power generations, transmission and distribution companies are getting ready to take their rightful place in this sector to offer efficient service for which load forecasting is an effective tool.

1 Keywords

Load forecasts with lead times from a few hours to seven days are essential in certain scheduling functions such as unit commitment and interchange evaluation. A wide variety of modeling techniques for STLF have been

suggested in the literature in ref. ??-6. Conventional load forecasting methods like regression method in ref. 7 The short term load forecast plays an important role in economic operation and reliability of power systems. The main objective of the STLTF is to advise the dispatcher in making a decision for economic dispatching. Therefore with an accurate model, it could also benefit dispatch systems to: supply load consistently estimate fuel allocation determine operational constraints determine equipment limitations

The second objective of the STLTF is security assessment and system updation. STLTF system requires offline historical data to do predictions. The data helps to run the model in advance, therefore allows dispatcher to provide corrective counter measure to the system.

In the proposed technique, historical load data obtained from DVC from the year 2010 to 2011 was used. The inputs used for the proposed method are, load at the particular time in the previous year, and two readings at half hour intervals of the same year along with the load of the half hour intervals in the present year. A mean absolute percentage error of 0.05% was achieved over the period of data which was tested on 1 week data. This represents on average a high degree of accuracy in the load forecast.

Load forecasting is one of the most important inputs for prediction of electricity prices. The vital initiative behind prediction involves increasing number of models that estimate future values of an indicator based on its past values.

Load forecasting can be done for different durations i.e. long term forecasts with lead time of more than one year, medium term forecasts with the lead time of one week to one year, short term forecasts with lead A historical data method has been used in this work to develop a model to make predictions of the load half an hour in advance, based on the relationship of processed data of previous year and data available for the current year. In this paper, the proposed short term load forecast using historical data (STLFHD) method has been tested on DVC load data in which the forecast has been made based on load data at a particular time of the previous year in steps of half hour and one hour and corresponding load data of the current year.

An assumption has been made that the environment factor of power production system is same on the present day and the same day in the last year. Also, the two real time loads in thirty minutes difference is included in the calculation to make the forecast value more accurate.

The equations devised for load forecasting using historical data are as given below: Mean Absolute Deviation (MAD) is the final accuracy measurement. This error measurement is the average of the absolute value of the error without regard to whether the error was an over estimate or underestimate.

2 Eqn (5)

3 Where

= actual load at particular time instant and = forecast load at that time.

The proposed technique was tested on historical data from the period 2010 to 2011. The data of first week February 2011 has been considered here for discussion and plotted graphs show for better understanding. Table 1 shows morning peak and Table 2 shows evening peak of Load data & load forecast data respectively. Where FL represents Forecast Load and HD represents Historical data Also, the results obtained clearly demonstrate that the proposed method is simple, fast, reliable, accurate, and effective for short term load forecasting and that this method can perform good prediction with least error. The results obtained in this work confirm the applicability as well as the efficiency of the proposed method in short-term load forecasting for the DVC grid load pattern located in eastern part of India. The method applied was able to determine the nonlinear relationship that exists between the historical load data supplied and on that basis, to make a prediction of what the load would be in the next half an hour.

The forecasting reliability of the proposed method was evaluated by computing the mean absolute error between the real time load and forecasted load. The results have shown that the prediction is more accurate with least error. Finally, we concluded this technique is simple and fast and could be an important tool for short term load forecasting for inter connected grid systems.

¹(J) 2011 December

²(J) 2011 December

³December



Figure 1:

I

Figure 2:

•

Figure 3:

1•

Figure 4: Figure 1 :

2 INTRODUCTION

Figure 5: Figure 2 :

23 II.

Figure 6: Figure 2 Fig. 3 :

L

Figure 7:

3 WHERE

1

Time	Year	01.02.11	05.02.11	07.02.11
			Load (MW)	Load (MW)
	2011	Load (MW)		
600	F FL	1487	1837	2049.5

Figure 8: Table 1 :

2

Time	Year	02.02.11	04.02.11	06.02.11
			Load (MW)	Load (MW)
	2011	Load (MW)		
	FL	1504	1744	1961
1800	HD	1505	1746	1964
	FL	1515.5	1754	1968.5
1830	HD	1516	1759	1967
	FL	1503	1750.5	1977.5
1900	HD	1501	1743	1976
	FL	1506	1749	1978
1930	HD	1508	1748	1978
	FL	1504.5	1761	1986
2000	HD	1503	1764	1988
	FL	1489.5	1805.5	1982
2030	HD	1489	1806	1981
	FL	1511.5	1864	1994
2100	HD	1513	1869	1997

Figure 9: Table 2 :

3

Date	HM	Methods CACM	BOPAM	STLFHD (Proposed Method)
01.02.11	0.853771	0.085133	0.649826	0.088758
02.02.11	1.823455	0.09901	0.721414	0.0955
03.02.11	2.181319	0.381517	1.265112	0.054279
04.02.11	1.635235	0.135338	0.824362	0.208704
05.02.11	1.687037	0.661841	1.644067	0.134027
06.02.11	0.682334	0.224032	0.664018	0.16012
07.02.11	1.143343	0.3451	0.906755	0.18286

Figure 10: Table 3 :

					11
					Volume XI Is-
					sue v v v v VII
					Version I
					Researches in
					Engineering
					Global Journal
					of
Date	HM	Methods CACM	BOPAM	Proposed Method STLFHD	
01.02.11	0.673998	0.120297	0.404542		
02.02.11	1.122309	0.178835	0.516869	0.08681	
03.02.11	1.588924	0.847906	1.126689	0.09902	
04.02.11	1.522361	0.260466	1.014949	0.045264	
05.02.11	1.18465	1.633852	1.571948	0.284057	
				0.171404	
06.02.11	0.543446	0.44989	0.71449	0.144841	
07.02.11	1.306622	0.728371	1.189224	0.215153	

Figure 11: Table 4 :

The authors acknowledge Damodar Valley Corporation for their constant support and cooperation in providing real time data to bring this work in this form.

.1 Global (J)

[Krajewski and Ritzman ()] , L J Krajewski , L R Ritzman . 1993.

[Rahman and Hazim (1993)] ‘A generalized knowledge-based short-term load forecasting techniques’. S Rahman , O Hazim . *Computing-A Fusion of Foundations, Methodologies and Applications*, (Heidelberg) 1993. April 2004. Springer-Verlag. 8 p. .

[Bakirtzis et al. ()] ‘A Neural Network Short Term Load Forecasting Model for Greek Power Systems’. A G Bakirtzis , V Petridis , S J Kiartzis , M C Alexiadis , A H Maissis . *IEEE Transactions on Power Systems* 1996. 11 p. .

[Papadaki et al. ()] ‘A novel approach to short-term load forecasting using fuzzy neuralnetworks’. S E Papadaki , J B Theocharis , S J Kiartzis , A G Bakirtzis . *IEEE Transactions on Power Systems* 1998. 13 p. .

[Moghran and Rahman (1989)] ‘Analysis and evaluation of five short-term load forecasting techniques’. I Moghran , S Rahman . *IEEE Transactions on Power Systems* October 1989. 4 p. .

[Chaturvedi et al. (2001)] ‘Fuzz-ified neural network approach for load for load fore casting problems’. D K Chaturvedi , P S Satsangi , P K Kalra . *International Journal on Engineering Intelli-gent Systems* March 2001. CRL Publishing. 9 (1) p. .

[Ranaweera et al. ()] ‘Fuzzy logic for short-term load forecasting’. D K Ranaweera , N F Hubele , G G Karady . *Elect. Power Energy Syst* 1996. 18 (4) p. .

[Eidesouky and Eikateb ()] ‘Hybrid adaptive techniques for electric-load forecasting using ANN and ARIMA’. A A Eidesouky , M M Eikateb . *IEE Proceedings-Generation, Transmission and Distribution* 2000. 147 p. .

[Yang et al. ()] ‘Identification of ARMAX model for short term load forecasting: an evolutionary programming approach’. H T Yang , C M Huang , C L Huang . *IEEE Trans. on Power Systems* 1996. 11 (1) p. .

[Chaturvedi et al.] ‘Improved generalized neuron model for short term load forecasting’. D K Chaturvedi , M Mohan , R K Singh , P K Kalra . *International Journal on Soft*

[Makridakis et al. ()] S Makridakis , S C Wheelwright , V E McGee . *Forecasting:Methods and Applications*, (NewYork) 1983. John Wiley & Sons. p. 86.

[Senjyu et al. ()] ‘Onehour-ahead load forecasting using neural network, IEEE transaction of power system’. T Senjyu , H Takara , K Uezato , T Funabasi . *IEEE Trans. on Power Systems* 2. T. Haida, S. Muto (ed.) 2002. 1994. 17 (1) p. . (Regression based peak load forecasting using a transformation technique)

[Operations Management, Strategy and Analysis] *Operations Management, Strategy and Analysis*, Addison-Weslev Publishing Company, Inc. p. 436.

[Gross and Galiana (1987)] ‘Short term load forecasting’. G Gross , F D Galiana . *Proceedings of the IEEE* December 1987. 75 (1212) p. .

[Bakirtzis et al. ()] ‘Short term load forecasting using fuzzy neural networks’. A G Bakirtzis , J B Theocharis , S J Kiartzis , K J Satsios . *IEEE Transactions on Power Systems* 1995. 1995. 10 p. . (IEEE Transactions on Power Systems)

[Can et al. ()] ‘Wavelet transfrom of meteorological parameters and gravity waves’. Z Can , Z Aslan , O Oguz , A H Siddiqi . *Annals Geophysics* 2005. 23 p. .